

## **Ouick Start**

- 1 Install the Fieldpiece Job Link® System app on your mobile device and sign up for an account if you're a new user
- 2 Remove the single screw of the yellow battery cover and install 2 x AAA batteries 3 Press of for 1 second to power on.
- 4 Open Measurements in the Job Link app and favorite the probe in the tool manager. 5 Tap () to zero.
- 6 View live measurements on your mobile device up to 1000 feet (305 meters) away.

#### What's Included

Job Link® System Manometer Probe 2 x AAA Batteries Tubing with brass fitting Bulk tubing Gas adapter Static pressure tip Operator's manual 1 Year limited warranty

## Description

The JL3MN Job Link® System Manometer Probe sends static pressure or gas pressure measurements directly to the Fieldpiece Job Link app up to 1000 feet (305 meters) away.

Use two JL3MN probes to do even more Because they are untethered, you don't need long hoses to measure differential pressures. Measure and view real-time return static, supply static, and total external static pressure all at once. Use your static pressure tip with short tubing for accurate static pressure measurements. Measure real-time inlet and manifold pressures with 2 Job Link manometers.

Mount your manometer to equipment for hands free use in tight spaces. The powerful rotating magnet holds tight even when the hose is tugged or the equipment shakes. Slide the switch and the app immediately knows which side of the system you're going to place your manometer probe.

#### Maintenance

CLEANING: Clean the exterior with a damp cloth. Do not use detergents or solvents. Do not apply pressurized air into the connection port.

BATTERIES: When the LED slow-blinks Red, the batteries must be replaced. Ensure the power is OFF. Remove the single screw from the yellow battery cover. Install 2 x AAA batteries. You can also monitor battery life in the Job Link app tool manager.

SENSOR CARE: Store JL3MN in a protective cover when not in use to prevent debris or foreign contaminants from entering the barb tip. Do not pressurize the probe above its max specification.

#### WARNING

Prevent damage, do not drill holes blindly into a plenum that houses the evaporator or heat exchanger. Do not place any part of the manometer on hot surfaces such as exhaust fumes. Doing so can cause personal injury, damage

equipment, and void warranty. Do no apply more than 11.6 psi.

## **Specifications**

Minimum Device Requirement:
BLE 4.0 devices running 105\*7.0 or Android\*\* 5.0
Compatible Media: Dry, non-corrosive gas
Pressure Port: Live connector of Resulte tubing (4.5 to 8mm ID)
Units of Measure: inWC, mmWC, mbar, psi, Pa Accuracy and Ranges:

inWC: ±(1.5% + 0.02) 0.00 to ± 60.00:

inWC: ±(1.5% + 0.02) 0.00 to ±60.00; mmWC: ±(1.5% + 0.5) 0.00 to ±150.00; mbar: ±(1.5% + 0.05) 0.00 to ±150.00; pis: ±(1.5% + 0.05) 0.00 to ±2.165; Pa: ±(1.5% + 5) 0 to ±1490.00; Maximum Overload Pressure: 321.08 inWC (11.6 ps; 80.0 kPa) Battery Jype: 2 x AAA, NBOA 24A, IECLRO3 Battery Jype: 2 x AAA, VBOA 24A, IECLRO3 Battery Jype: 150 hours typical alkaline. IED slow-blinks red when battery replacement is needed.

battery replacement is needed.
Auto Power off: 2 hours (APO can be disabled)
Wireless Range: 1000 feet (305 meters) line of sight.
Obstructions affect distance.
Radio Frequency: 24 GHz
Operating Environment: -10°F to 122°F (-23°C to 50°C) at <75%

Storage Temperature: -10°F to 140°F (-23°C to 60°C) at <80% RH (with batteries removed)

Temperature Coefficient: 0.1 x (specified accuracy) per 1.8°F

(-10°F to 64°F, 82°F to 122°F), per 1°C (-23°C to 18°C, 28°C to

Weight: 0.30 lbs (137 g)





Press for 1 second to power ON/OFF. Tap to zero measurements.

#### **LED Color Indications**

Green slow blink: normal operation Red slow blink: batteries need to be replaced

#### **Supply or Return Side Switch**

The Job Link® System app knows which side you have selected for each probe. Select P1 or P2 and place it on the system appropriately.





(Supply) (Blue)




#### **Static Pressure**

Static pressure testing ensures if the equipment is operating within factory specifications.

- Zero your JL3MN while in ambient pressure with any tubing/probes attached before taking measurements. For measurements less than 2 inWC, take reading within 1 minute after zeroing for best accuracy.
- 2 Use the included static pressure tip when checking static pressure in an airflow stream. NOTE: The red arrow on the static probes should point toward the airflow of the stream.
- 3 Place a JL3MN before and after the filter to measure your filter pressure drop (B) (A).
  4 Place a JL3MN before and after the coil to
- Place a JLSMN before and after the coil of the measure your coil pressure drop (0 0).

  Place a JLSMN in the inlet and outlet air of the equipment to measure your total external static pressure (0 0). Check with manufacturer to determine TESP test locations.

  NOTE: If you are in an environment where the
- NOTE: If you are in an environment where the temperature is noticeably changing while you are taking your reading, it is advised that you disconnect the probe from the tubing and ZERO it relative to the ambient air before each reading.



### **Gas Pressure**

Prevent symptoms like rough starts or overheating your heat exchanger by checking your gas pressure.

- See manufacturer's specification for target inlet and outlet fuel or gas pressures.
   Shut off main gas supply power to furnace.
- Shut off main gas supply power to furnace.
   Zero your JL3MN while at ambient pressure with tubing attached before taking measurements.
- 5 Remove outlet pressure tap screw and insert the brass screw fitting of the hose into the outlet pressure tap of the gas regulator.

NOTE: Some pressure taps have a 5/16" boss instead of an insert screw. In this case, use the included 5/16" adapter tube. Loosen the tap screw about 1 revolution and slide the tube over the boss.



- 6 If you suspect high or low inlet pressure to the regulator, connect the JL3MN to the inlet tap.
  7 Put furnace into operation and begin to take
- 7 Put furnace into operation and begin to take measurements.

#### Auto Power Off (APO)

The probe will automatically power off after 2 hours. To disable APO until powered off, while power is on tap  $\oplus$  twice. The LED will briefly blink red. To enable APO, while power is on tap  $\oplus$  twice. The LED will briefly shine red.

## Certifications and Module IDs









ROMS Restriction of Hazardous

IC: Industry Canada 22518-BT003

IFETEL: Federal Telecom Institute RCPFI2A18-0235

## FCC Statement

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These

This equipment has been tested and found to comply with the limits for a Class B displa device, pursuant to Part 1s of the ECR Delus. These limits are designed to provide reasonable protection against hamful interference in a residential installation.

This equipment generates, uses and can radiate radio frequency energy and, find installed and used in accordance with the instructions, may cause hamful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause hamful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one of the following measures.

Increase the separation between the equipment and receiver.

Connect the equipment into an outle on a circuit different from that to which the receiver is connected.

Consout the dealer or an experience and/off Vechnican for help.

FCC Caution: To assure continued compliance, any changes or modifications not expressly approved by the party responsible from compliance could would be user's authority to operate this equipment. (Example - use only shielded interface cables when connecting to computer or peripheral devices.).

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

This device complies with Industry Canada licence-exempt RSS-247 This device complies with industry Canada licence-evempt RSS-247 standard. Operation is subject to the following two conditions: (1) this device may not cause interference, and (2) this device must accept any interference, including interference that may cause undesired operation of the device.

IC Radiation Exposure Statement: This equipment complies with IC KSS-102 radiation exposure limit set forth for a uncontrolled environment. This equipment should be installed and operated with minimum distance 1.5 cm between the addition and work of the installed and operated with minimum distance 1.5 cm between the addition and work but the device.

minimum distance 0.5 cm between the radiator and your body. Fieldpiece Instruments 1636 West Collins Avenue, Orange, CA 92867

## **IFETEL Statement**

La operación de este equipo está sujeta a las siguientes dos condiciones: (1) es posible que este equipo o dispositivo no cause interferencia perjudicial y (2) este equipo o dispositivo debe aceptar cualquier interferencia, incluyendo la que pueda causar su operación

no desendo.

The operation of this equipment is subject to the following two conditions: (1) this device or device may not cause harmful interference, and (2) this device or device must accept any interference, including interference that may cause undesired operation.

## Limited Warranty

This probe is warranted against defects in material and workmanship for one year from date of purchase from an authorized Fieldpiece dealer. Fieldpiece will replace or repair the defective unit, at its option, subject to verification of the defect.

To verification of the defect.

This warranty does not apply to defects resulting from abuse, neglect, acident, nuanthorized repair, alteration, or unreasonable use of the instrument.

Any implied warranties arising from the sale of a Fieldpiece product, including but not limited to implied warranties of merchantability and fitness for a particular purpose, are limited to the above. Fieldpiece shall not be liable for loss of use of the instrument or other incidental or consequential damages, expenses, or economic loss, or for any claim of such damage, expenses, or economic loss, State leaws vary. The above limitations or exclusions may not apply to you.

#### **Obtaining Service**

For international customers, warranty for products purchased outside of the U.S. should be handled through local distributors. Visit our website to find your local distributor.



© Fieldpiece Instruments, Inc 2024; v17.5

## Fieldpiece Job Link® System

Premium Pipe Clamp Probe



## Quick Start

- 1 Install the Fieldpiece Job Link® system app on your mobile device and sign up for an acc if you're a new user.
- Remove the single screw of the top rubberized battery cover and install 2 x AAA batteries.
- 3 Press & for 1 second to power on. 4 Open Measurements in the Job Link® app and
- favorite the probe to the tool manager.

  5 Viewlivemeasurementsonyourmobiledevice up to 1000 feet away.

#### What's Included

Job Link® System Premium Pipe Clamp Probe 2 x AAA Batteries Emery Cloth for Cleaning Pipes Operator's Manual

1 Year Limited Warranty

#### WARNING

The entire JL3PC may become hot when testing hot pipes or cylinders. Use caution handling.

## Description

The JL3PC Job Link® System Premium Pipe Clamp Probe sends long range wireless pipe temperature measurements directly to the Fieldpiece Job Link® system mobile app. Take advantage of Rapid Rail™ sensor technology for extremely fast and accurate measurements that surpasses Title 24 requirements.

The Rapid Rail™ thermocouple is specifically designed to work on HVACR electrically (and thermally) conductive piping and uses the pipe itself to complete the circuit, resulting in the highest temperature accuracy!
Navigate cramped spaces using the narrow

jaw. Rubberized grips and ergonomic design supply comfort and control. Work on a wide range of pipes from 1/4" to 1-3/8". Pipe diameters are etched into sides of the clamp for quick reference.

#### Maintenance

**CLEANING**: Clean the exterior with a damp cloth. Do not use detergents or solvents.

BATTERIES: When the LED slow blinks Red, the batteries must be replaced. Ensure the power is OFF. Remove the single screw from the top rubberized battery cover. Install 2 x AAA batteries. You can also monitor battery life in the Job Link® app tool manager.

CALIBRATION: The JL3PC is wireless so it doesn't need to be calibrated as often as wired thermocouples. To verify accuracy, submerge just the sensor into ice water. Depending on atmospheric pressure and water purity, the measurement will be 32°F ± 1°F. If calibration is required, use the tool manager in the app to adjust the offset for that particular tool

## **Specifications**

nimum Device Requirement: BLE 4.0 devices running iOS® 7.0 or Android™ 5.0

Pipe Contact Surface Compatibility: Electrically conductive Pipe Size Compatibility: 1/4" to 13/8" (6.4mm to 34.9mm) OD Sensor Type: Rapid Rail" thermocouple (nickel chromium/nickel aluminum)

Measurement Feedback: Beeper and LED Measurement Range: -50°F to 257°F (-46°C to 125°C)
Plastic body and wire insulation are designed to withstand a

maximum continuous temperature of 257°F (125°C).

maximum continuous temperature of 257°F (125°C). Stabilization Time: 3 seconds 5 prical Accuracy: ±1.0°F (±0.6°C)\*\*
"Meets California Title 24 requirements Battery Type: 2 x AAA, NEDA 24A, IEC (R03 Battery Life: 150 hour typical alkaline. LED blinks red when battery replacement is needed. Auto Power Off: 2 hours (APO can be disabled) Wireless Range: 1000 feet (26 one meets) line of sight. Obstructions affect dislance. 2 Active Research 2 Active Resear

Radio Frequency: 2.4 GHz
Operating Environment: -4°F to 122°F (-20°C to 50°C) at <75%

RH

Storage Temperature: -4"F to 140"F (-20"C to 60"C), 0 to 80% RH

(with batteries removed)

Temperature Coefficient: 0.1 x (specified accuracy) per 1.8"F

(-4"F to 64"F, 82"F to 122"F), per 1"C (-20"C to 18"C, 28"C to 50"C)

Water Resistant: Designed to IPS5

Water Resistant: Designed to IPS5

## Operation

Press for 1 second to power ON/OFF.

#### **LED Color Indications**


Green slow blink: normal operation Yellow blink: open thermocouple circuit Red slow blink: batteries need to be replaced

#### **High or Low Side Switch**

The Job Link® system app knows which side you have selected for each probe. Select Suction line or Liquid line and place it on the



Liquid Line



Traditional pipe clamps sit on top of the pipe surface. Some sensors touch the pipe, some have a material between the pipe and the sensor. They can be affected by wind, heat, corrosion, insulation, paint, dirt, etc.

The Rapid Rail™ sensor uses the pipe itself to complete the thermocouple circuit. The pipe is part of the sensor! If you get a measurement, you know it's correct.

Because the pipe is the thermocouple junction, all you need is enough contact for conductivity. This means the clamp can sit on an angle or on a bend without loss in performance.

There is a beeper and an LED to indicate whether or not the circuit is closed and a temperature is being measured:

Double beep and yellow LED = Open Circuit Single beep and green LED = Closed Circuit

If you don't get a measurement, there's something on the pipe that's blocking the electrical circuit (and accuracy). Sometimes you can slightly rotate the clamp back and forth around the pipe to cut through contaminants. Sometimes you need to sand the pipe a bit.

## **Remote Data Logging**

(Data logging will be available shortly after time of printing. Look for updates.)

Use the Job Link® system mobile app to program the JL3PC to log measurements starting at a specific time of day for up to 7 days. Auto power off disables.

- Make sure JL3PC is powered OFF.
   Open the Job Link® system mobile app.
- 3 Press & for 5 seconds to enter data logging mode. The LED will shine solid green.
- 4 Set up the probe's data logging parameters within the app. The LED will blink green while the app is sending setup instructions. The LED will slow blink blue when waiting for programmed start time to occur.
- 5 Place the JL3PC on the system.
- 6 When the programmed start time is reached, the LED will very slowly blink green to indicate data logging has begun. When the programmed span has finished, the
- LED blinks and powers OFF.
- 8 Repeat steps 1-3 and use the app to extract your data log from the JL3PC.

#### Auto Power Off (APO)

If the clamp hasn't been opened/closed or the button pressed, it will automatically power off after 2 hours. To disable APO until powered off, while power is on tap & twice. The LED will briefly blink red. To enable APO, while power is on tap o twice. The LED will briefly shine red.

## Limited Warranty

This probe is warranted against defects in material and workmanship for one year from date of purchase from an authorized Fieldpiece dealer. Fieldpiece will replace or repair the defective unit, at its option, subject to verification of the defect.

This warranty does not apply to defects resulting from abuse, neglect, accident, unauthorized repair, alteration, or unreasonable use of the instrument.

use of the instrument.

Any implied warranties arising from the sale of a Fieldpiece product, including but not limited to implied warranties of merchantability and fitness for a particular purpose, are limited to the above. Fieldpiece shall not be liable for loss of use of the instrument or other incidental or consequential damages, expenses, or economic loss, or for any claim of such damage, expenses, or economic loss.

State laws vary. The above limitations or exclusions may not apply town.

## **Obtaining Service**

For international customers, warranty for products purchased outside of the U.S. should be handled through local distributors. Visit our website to find your local distributor.



© Fieldpiece Instruments, Inc 2021; v17

## Certifications and Module IDs



tory Compliance Mark Ø Waste Electrical and Electronic Equipmen



Restriction of Hazardous Substances Compliant IC: Industry Canada 22518-BT003 IFETEL: Federal Telecom Institute

## FCC Statement

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Bules. These limits are designed to provide reasonable protection against harmful interference in a residential installation.

This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no quaramete that interference will not occur in a particular installation. If this equipment does cause harmful interference to add not relevision presention, which can be determined by turnion and the properties of the control of the properties radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one of the following measures:

interference by one of the following measures:

Reorient or relocate the receiving antenna.

Increase the separation between the equipment and receiver.

Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.

Consult the dealer or an experienced radio/TV technician for help.

FCC Caution: To assure continued compliance, any changes or modifications not expressly approved by the party responsible for compliance could widthe user's authority to operate this equipment.

(Example - use only shielded interface cables when connecting to computer or perinheal eduries).

computer or peripheral devices). This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference eceived, including interference that may cause undesired operation

This device complies with Industry Canada licence-exempt RSS-247 standard. Operation is subject to the following two conditions: (1) this device may not cause interference, and (2) this device must accept any interference, including interference that may cause undesired operation of the device.

IC Radiation Exposure Statement: This equipment complies with IC RSS-102 radiation exposure limit set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance 0.5 cm between the radiator and your body. Fieldpiece Instruments 1636 West Collins Avenue, Orange, CA 92867

## IFETEL Statement

La operación de este equipo está sujeta a las siguientes dos condiciones: (1) es posible que este equipo o dispositivo no cause interferencia perjudicial y (2) este equipo o dispositivo debe aceptar cualquier interferencia, incluyendo la que pueda causar su operación

conquer interferenta, insuperior to give peeu usussa su operation no desenda.

The operation of this equipment is subject to the following two conditions: (1) this device or device may not cause harmful interference, and (2) this device or device must accept any interference, including interference that may cause undesired operation.

## **ANATEL Statement**

sales@GlobalTestSupply.com

Este equipamento não tem direito à proteção contra interferência prejudicial e não pode causar interferência em sistemas devidamente

# Fieldpiece

Job Link® System Pressure Probe OPERATOR'S MANUAL Model JL3PR

## **Quick Start**

- 1 Install the Fieldpiece Job Link® system app on your mobile device and sign up for an account if you're a new user.
- 2 Remove the single screw of the vellow battery
- cover and install 2 x AAA batteries. 3 Press of for 1 second to power on.
- 4 Open Measurements in the Job Link® app and favorite the probe to the tool manager
- 5 Viewlive measurements on your mobile device up to 1000 feet away.

#### What's Included

- Job Link® System Pressure Probe 2 x Replacement Gaskets
- 2 x AAA Batteries Operator's Manual
- . 1 Year Limited Warranty

## WARNING

Hand turn the female fitting to connect and disconnect DO NOT use the plastic body to increas leverage. Doing so can cause damage, leaks, and void warranty. Do not apply more than 800 psig.

## Description

The JL3PR Job Link® System Pressure Probe sends long range wireless pressure measurements directly to the Fieldpiece Job Link® system mobile app.

Easily reach service ports in tight spaces using the angled 1/4" fitting. The rubberized protective housing is both ergonomic and rugged for daily use.

Flip the switch to red or blue and the app immediately knows which side of the system you're going to place your pressure probe.

The perfect balance of size and capability

gives you exactly what you need to diagnose systems day in and day out quickly and

## Maintenance

CLEANING: Clean the exterior with a damp cloth. Do not use detergents or solvents

BATTERIES: When the LED slow blinks Red. the batteries must be replaced. Ensure the power is OFF. Remove the single screw from the yellow battery cover. Install 2 x AAA batteries. You can also monitor battery life in the Job Link® app tool manager.

GASKET: The black rubber gasket that seals the pressure probe to the service port may become worn over time potentially causing a leak. This results from overtightening or connecting to damaged service port fittings.

- 1 Use needle nose pliers or a similar tool to unscrew the Schrader valve depressor from the gasket.
- 2 Remove and replace the worn gasket.
- 3 Screw the depressor back into the gasket.

Schrader Valve Depressor

## Specifications

Minimum Device Requirement:
BLE 4.0 devices running 105° 7.0 or Android™ 5.0
Sensor Type: Relative pressure
Connector Type: Shandard 114′ NPT female flare fitting (angled)
Measurement Range:
29′ HgV to 580 psig, 74 cmHgV to 0 to 4000 kPa
Accuracy:

Accuracy:

25° HgV to "HgV: ±0.2" HgV; 74 cmHgV to 0 cmHgV: ±1 cmHgV
0 to 200 psig: ±1 psig: 0 to 1378 M2a: ±7 kPa
200 to 580 psig: ±1 psig: 0 to 1378 M2a: ±7 kPa
200 to 580 psig: ±2 psig: 1378 to 4000 kPa: ±14 M2a
Maximum Overload Pressure: 800 psig: (5500 kPa)
Battery Type: 2 x AAA, NEDA 24A, IEC I.803
Battery Life: 150 hours typical alkaline. LED blinks red when battery replacement is needed.
Auto Power Off: 2 hours (APO can be disabled)
Wireless Range: 1000 feet (105 meters) line of sight.
Obstructions affect distance.
Radio Frequency: 2.4 GHz
RH
RH
Storage Temperature: -4"F to 122" F (-20"C to 50"C) at <75%
RH
Storage Temperature: -4"F to 140" F (-20"C to 60"C). 0 to 80% RH

Storage Temperature: -4°F to 140°F (-20°C to 60°C), 0 to 80% RH (with batteries removed)

Temperature Coefficient: 0.1 x (specified accuracy) per 1.8°F

(-4°F to 64°F, 82°F to 122°F), per 1°C (-20°C to 18°C, 28°C to 50°C) Weight: 0.39 lbs (177 a)

Water Resistant: Designed to IP55

## Operation

(I) Press for 1 second to power ON/OFF.

#### **LED Color Indications**

Green slow blink: normal operation Red slow blink: batteries need to be replaced

#### **High or Low Side Switch**

The Job Link® system app knows which side you have selected for each probe. Select Suction line or Liquid line and place it on the system appropriately.





## **Remote Data Logging**

(Data logging will be available shortly after time of printing. Look for updates.)

Use the Job Link® system mobile app to program the JL3PR to log measurements starting at a specific time of day for up to 7 days Auto power off disables.

- Make sure JL3PR is powered OFF.
   Open the Job Link® system mobile app.
- 3 Press of for 5 seconds to enter data logging mode. The LED will shine solid green.
- 4 Set up the probe's data logging parameters within the app. The LED will blink green while the app is sending setup instructions. The LED will slow blink blue when waiting for programmed start time to occur. Place the JL3PR on the system.
- 6 When the programmed start time is reached, the LED will very slowly blink green to indicate data logging has begun.

  7 When the programmed span has finished, the
- LED blinks and powers OFF.
- 8 Repeat steps 1-3 and use the app to extract your data log from the JL3PR.

#### Auto Power Off (APO)

The pressure probe will automatically power off after 2 hours. To disable APO until po off, while power is on tap o twice. The LED will briefly blink red. To enable APO, while power is on tap o twice. The LED will briefly shine red.

#### **Auto Calibration**

Automatically calibrate your JL3PR by ensuring the sensor is open to atmosphere when you power ON the probe.

## Limited Warranty

This probe is warranted against defects in material and workmanship for one year from date of purchase from an authorized Fieldpiece dealer. Fieldpiece will replace or repair the defective unit, at its option, subject to verification of the defect.

This warranty does not apply to defects resulting from abuse, neglect, accident, unauthorized repair, alteration, or unreasonable use of the instrument.

Any implied warranties arising from the sale of a Fieldniece product Any implied warranties arising from the sale of a Fieldpiece product, including but not limited to implied warranties of merchantability and fitness for a particular purpose, are limited to the above. Fieldpiece shall not be liable for loss of use of the instrument or other incidental or consequential damages, expenses, or economic loss, or for any claim of such damage, expenses, or economic loss, State leaws vary. The above limitations or exclusions may not apply lower.

#### **Obtaining Service**

For international customers, warranty for products purchased outside of the U.S. should be handled through local distributors. Visit our website to find your local distributor.



© Fieldpiece Instruments, Inc 2021; v17

## Certifications and Module IDs



**C**€





ory Compliance Mark



Rohs Restriction of Hazardous Substances Compliant IFETEL: Federal Telecom Institute

## FCC Statement

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These

limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, energy and, if not installed and used in accordance with the instructions, any cause harmful interference to acido communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one of the following measures:

Reorient or relocate the receiving antenna.

Increase the separation between the equipment and receiver.

Connect the equipment into an outlet on a circuit different from that to which the acresions is consorted.

that to which the receiver is connected. Consult the dealer or an experienced radio/TV technician for help.

FCC Caution: To assure continued compliance, any changes or FCC Caution: To assure continued compliance, any changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate this equipment. (Example - use only shielded interface cables when connecting to computer or periphenal devices). This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

This device complies with Industry Canada licence-exempt RSS-247 standard, Operation is subject to the following two conditions: (1) this device may not case interference, and (2) this device must accept any interference, including interference that may cause undesired operation of the device.

IC Radiation Exposure Statement: This equipment complies with CSSS-130 solutions accessed before the control of the complete of the control of the complete of the control of t

with IC RSS-102 radiation exposure limit set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance 0.5 cm between the radiator and your body. Fieldpiece Instruments 1636 West Collins Avenue, Orange, CA 92867

### **IFETEL Statement**

La operación de este equipo está sujeta a las siguientes dos condiciones: (1) es posible que este equipo o dispositivo no cause interferencia perjudicial y (2) este equipo o dispositivo debe aceptar cualquier interferencia, incluyendo la que pueda causar su operación

The operation of this equipment is subject to the following two conditions: (1) this device or device may not cause harmful interference, and (2) this device or device may not cause harmful interference, and (2) this device or device must accept any interference, including interference that may cause undesired operation.

### **ANATEL Statement**

Este equipamento não tem direito à proteção contra interferência prejudicial e não pode causar interferência em sistemas devidamente

This equipment is not subject to the protection from harmful interference and may not cause interference with duly authorized

## Fieldpiece

Job Link® System Flex Psychrometer

Probe **OPERATOR'S** MANUAL





## Quick Start

- 1 Install the Fieldpiece Job Link® system app on your mobile device and sign up for an account if you're a new user.
- 2 Remove the single screw of the yellow battery cover and install 2 x AAA batteries.
- 3 Press & for 1 second to power on.
  4 Open Measurements in the Job Link® app and favorite the probe to the tool manager
- 5 Remove protective slip cover from tip.
- 6 Viewlivemeasurementsonyourmobiledevice up to 1000 feet away.

#### What's Included

Job Link® System Flex Psychrometer Probe 1 Protective Slip Cover

- 2 x AAA Batteries
- Operator's Manual 1 Year Limited Warranty

#### WARNING

Prevent damage, do not drill holes blindly into a plenum tha uses the evaporator or heat exchanger.

## Description

The JL3RH Job Link® System Flex Psychrometer Probe sends air measurements directly to the Fieldpiece Job Link® app up to 1000' away.

Measure %RH, dry bulb, wet bulb, dew point, and enthalpy at a register/grille, in the duct, or just walking around. Bend the flexible probe and slide the magnet to conveniently configure the JL3RH to your situation.

The rubberized protective housing is both ergonomic and rugged for daily use. Flip the switch and app immediately knows which side of the system you're going to place your psychrometer probe.

Use the long wireless range, strong magnet, and flexible probe for quick and easy psychrometrics testing.

## Maintenance

CLEANING: Clean the exterior with a damp cloth. Do not use detergents or solvents. Do not touch the sensor.

BATTERIES: When the LED slow blinks Red, the batteries must be replaced. Ensure the power is OFF. Remove the single screw from the yellow battery cover. Install 2 x AAA batteries. Monitor battery life in the app's tool manager.

SENSOR CARE: Cover the sensor with the slip cover when not in use. Extreme conditions or exposure to solvent vapor may offset the RH sensor. To re-calibrate, place the sensor in a controlled environment of 75%RH and between 68°F - 86°F for a period of 24 hours. To create a 75%RH environment, add wet salt to a clean open container (bottle cap). Be careful to not let the solution touch the probe. Place this container and the probe in a large sealed bag at room temperature, undisturbed for 24 hours.

## **Specifications**

Minimum Device Requirement: BLE 4.0 devices running iOS™ 7.0 or Android™ 5.0

Battery Type: 2 x AAA, NEDA 24A, IECLR03
Battery Life: 150 hours typical alkaline. LED blinks red when battery replacement is needed.
Auto Power Off: 2-bours (APO can be disabled)
Wireless Range: 1000 feet (305 meters) line of sight.
Obstructions affect distance.
Radio Frequency: 2-4 GHz
Operating Environment: -4°F to 122°F (-20°C to 50°C) at <75%
BH

Storage Temperature: -4°F to 140°F (-20°C to 60°C), 0 to 80% RH

Storage Temperature: -4" to 140" t -20" to 60" t), 0 to 80% RH (with batteries removed)

Temperature Coefficient: 0.1 x (specified accuracy) per 1.8" f (32" to 64"; 82" to 122"), per 1"C (0"C to 18"C, 28"C to 50"C)

Weight: 0.33 ii (510 g)

25" (235mm) length

#### Relative Humidity (%RH)

Hysteresis: ±1%RH typical (Excursion of 10% to 90% to 10%RH)
Measurement Range: 0%RH to 100%RH
Accuracy: (Ar 73.4°F (23°C))
±2.5% (10%RH to 90%RH); ±15%) < 10%RH, >90%RH Response
Time: 60 seconds typical for 90% of total range

#### Temperature

Measurement Range: -40°F to 250°F (-40°C to 121°C) Accuracy:  $\pm$ (1°F) 32°F to 113°F,  $\pm$ (0.5°C) 0°C to 45°C;  $\pm$ (2°F) -40°F

to 32°F, 113°F to 250°F, ±(1°C) -40°C to 0°C, 45°C to 121°C

## Operation



(I) Press for 1 second to power ON/OFF.

#### **LED Color Indications**

Green slow blink: normal operation Red slow blink: batteries need to be replaced


#### **Supply or Return Side Switch**

The Job Link® system app knows which side you have selected for each probe. Select Supply air or Return air and place it on the system appropriately

#### **Magnetic Hanger**

You can slide the magnet to where you need it. Slide it to the top and reach high grilles/

The magnet also holds the psychrometer in place when testing in duct air. Just bend the probe and slide into a 3/8" (10mm) hole in the



#### Remote Data Logging

(Data logging will be available shortly after time of printing. Look for updates.)

Use the Job Link® system app to program the JL3RH to log measurements starting at a specific time of day for up to 7 days. Auto power off disables.

- Make sure JL3RH is powered OFF.
- 2 Open the Job Link® system mobile app. 3 Press & for 5 seconds to enter data logging
- mode. The LED will shine solid green.
- 4 Set up the probe's data logging parameters within the app. The LED will blink green while the app is sending setup instructions. The LED will slow blink blue when waiting for programmed start time to occur.
- 5 Place the JL3RH on the system.6 When the programmed start time is reached,
- the LED will very slowly blink green to indicate data logging has begun.
- 7 When the programmed span has finished, the LED blinks and powers OFF.
  - 8 Repeat steps 1-3 and use the app to extract your data log from the JL3RH.

#### Auto Power Off (APO)

The probe will automatically power off after 2 hours. To disable APO until powered off, while power is on tap  $\oplus$  twice. The LED will briefly blink red. To enable APO, while power is on tap twice. The LED will briefly shine red.

## Limited Warranty

This probe is warranted against defects immaterial and wordmanship for one year from date of purchase from an authorized Fieldpiece dealer. Fieldpiece will replace or repair the defective unit, at its object to werification of the defect. Register your Fieldpiece product. This warranty does not apply to defects resulting from abuse, neglect, accident, unauthorized repair, alteration, or unreasonable use of the instrument. Any implied warranties a rising from the sale of a Fieldpiece product, including but not limited to implied warranties or merchantability and fitness for a nariorization numerous emitting to merchantability and fitness for a nariorization numerous.

merchantability and fitness for a particular purpose, are limited to the above. Fieldpiece shall not be liable for loss of use of the instrument or other incidental or consequential damages, expenses, or economic loss, or for any claim of such damage, expenses, or onomic loss. State laws vary. The above limitations or exclusions may not apply

## **Obtaining Service**

For international customers, warranty for products purchased outside of the U.S. should be handled through local distributors.



© Fieldpiece Instruments, Inc 2021; v17

## Certifications and Module IDs



Ø



ry Compliance Mark

Waste Electrical and Electronic Equipmen

RoHs Restriction of Hazardous

Substances Compliant IFETEL: Federal Telecom Institute

## FCC Statement

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Bules. These limits are designed to provide reasonable protection against harmful interference in a residential installation.

This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no quaramete that interference will not occur in a particular installation. If this equipment does cause harmful interference to did not relevision presention, which can be determined by turnion and the properties of the control radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one of the following measures:

. Reorient or relocate the receiving antenna.

. Reorient or relocate the receiving antenna.
Increase the separation between the equipment and receiver.
Connect the equipment into an outlet on a circuit different from
that to which the receiver is connected.
Consult the dealer or an experienced radio/TV technician for help.
FCC Caution: To assure continued compliance, any changes or
ordifications not expressly approved by the party responsible for
compliance could void the user's authority to operate this equipment.
(Example - use only shielded interface cables when connecting to
computer or preinfeared devices).

computer or peripheral devices). computer or peripheral enewtee).
This device complies with Part 15 of the FCC Rules, Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

rice complies with Industry Canada licence-exempt RSS-247 standard. Operation is subject to the following two conditions: (1) this device may not cause interference, and (2) this device must accept any interference, including interference that may cause undesired ation of the device.

IC Radiation Exposure Statement: This equipment complies with IC RSS-102 radiation exposure limit set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance 0.5 cm between the radiator and your body. Fieldpiece Instruments 1636 West Collins Avenue, Orange, CA 92867

## IFETEL Statement

La operación de este equipo está sujeta a las siguientes dos condiciones: (1) es posible que este equipo o dispositivo no cause interferencia perjudicial y (2) este equipo a dispositivo debe aceptar cualquier interferencia, incluyendo la que pueda causar su operación

cuaquem intervencia, incluyenou ha que puedo acusar su operación no deseada.

The operation of this equipment is subject to the following two conditions: (1) this device or device may not cause harmful interference, and (2) this device or device must recept any interference, including interference that may cause undesired operation.

## **ANATEL Statement**

Este equipamento não tem direito à proteção contra interferência prejudicial e não pode causar interferência em sistemas devidamente

This equipment is not subject to the protection from harmful interference and may not cause interference with duly authorized systems.