## **100A/200A/400A REVENUE GRADE SPLIT CORE CURRENT TRANSFORMERS**



DENT's SRL Series hinged split-core current transformers are designed for Revenue Grade applications that require maximum accuracy and precision. The superior performance, robust design, and unique shrouded snap, lock & tilt top of the SRS Series CTs make them ideal for field installation in high accuracy current measurement applications such as energy and demand metering, tenant submetering and load surveys. Revenue Grade performance of these CTs meets or exceeds the accuracy specifications of IEC 61869-2 Class 0.2; IEC 60044-1 Class 0.3; and IEEE C57.13 Class 0.3.

The SRL Series CTs are UL2808 and CSA C22.2 No. 61010-1 listed as stand-alone products, CE marked, RoHS compliant, and are 600V CAT III rated devices. They are available for current inputs up to 400 Amps with 8 foot long, 18 AWG MTW UL1015 twisted pair leads.

KEY SPECIFICATIONS			
Window Size	1.25" (31.75mm)		
Current Range	100A Model: 1.0—200A AC 200A Model: 2.0—400A AC 400A Model: 4.0—500A AC		
Output	333.3mV at rated current		
Ratio Error	+/-0.2% at rated current (typical)		
Phase Error	< 0.2°		
Meets the Accuracy Requirements for <sup>1</sup>	IEC 61869-2 Class 0.2 IEC 60044-1 Class 0.2 IEEE C57.13 Class 0.3		

ELECTRICAL	
Output	333.3mV at rated current
Wire Polarity	White = Hi, positive (+) Black = Low, negative (-)
Frequency Range	40 to 400 Hz


MECHANICAL	
Case Material	120°C UL Recognized Plastic
Leads	8ft (2.4M) black and white twisted pair 18 AWG MTW UL1015, 600V, 105°C double insulated
Operating Temperature	-40°C to 70°C (-40°F to 158°F)

Operating Temperatu	ire	-40°C to 70°C (-40°F to 158°F)
SAFETY		
Working Voltage		600 VAC, Category III
Dielectric Strength		7400 VAC
Certification	C CUL US LISTED E477005	Conforms to: UL Listed to UL 2808 Certified to: CSA STD C22.2 No. 61010-1









DIMENSIONS			
WINDOW	Α	В	С
1.25" 31.75mm	3.3" 83.81mm	3.1" 78.74mm	1.3" 33.04mm
PART NUMBERS			
CT-SRL-100-U/B	100A Revenue Grade Split Core		
CT-SRL-200-U/B	200A Revenue Grade Split Core		
CT-SRL-400-U/B	400A Revenue Grade Split Core		

 $<sup>^{1}</sup>$  When CT phase shift is set as follows:  $100A = 0.06^{\circ}$ ,  $200A = 0.06^{\circ}$ ,  $400A = -0.06^{\circ}$ 

All specifications contained in this document are subject to change without notice. © DENT INSTRUMENTS, INC.