

LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm

ICON™ Corrosion-Free
PROCESS CONTROLS Instrumentation Equipment™



LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm

ICON™ Corrosion-Free
PROCESS CONTROLS Instrumentation Equipment™

ProAlert®

The Next Big Thing in Liquid Monitoring

All Plastic
NEMA 4X
Enclosure

Built in
Visual Alarm

Features


- ✓ High Intensity Red Alarm Light (Optional Blue Lens)
- ✓ Pulse to Relay Output
- ✓ Super Loud 108dB Audible Alarm
- ✓ Silence Function | Light Remains On
- ✓ Rugged NEMA 4X Industrial Enclosure
- ✓ External Wall Mounting Brackets
- ✓ High Impact Plastic Polycarbonate Shell
- ✓ Includes 6' Power Cord + Watertight Cord
- ✓ Completely Pre-Wired
- ✓ Extra Output Contact to Remote Alarm or PLC



Alarm Test

108dB
Audible Alarm

Latching Audio Alarm
Silence Switch



Flow



Liquid Level



Analytical



Pressure




Leak
Detection



Optional Blue Lens
for Enhanced Visibility

3 Easy Mounting Options




Wall Mount



Panel Mount



Pole/Pipe Mount



LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm

ICON™ Corrosion-Free
PROCESS CONTROLS Instrumentation Equipment™

Typical Applications

- ✓ High High | Low Level Indication for Tanks | Sumps
- ✓ Bag | Filter Change Out
- ✓ Leak Detection
- ✓ Flow | No Flow Sensors | Pump Protection
- ✓ Upset Condition Notification

Specifications

- ✓ Dimensions | 7" X 5" X 4.5"
- ✓ Enclosure | NEMA 4X
- ✓ Weight | 2.1 lbs.
- ✓ 24VDC
- ✓ 100 - 240VAC (with DC adapter)

Model Selection

ProAlert® PA223

- PNP | NPN | Dry Contact Input
- Audible | Visual Alarm

ProAlert® PA223-PR (PA223-PR-2 for 2 relays)




- PNP | NPN
- 10AMP AC | 10AMP DC Relay Output
- Audible | Visual Alarm

ProAlert® PA223-LD


- PNP | NPN | Dry Contact Input
- Audible | Visual Alarm
- Leak Detection Module for Leak Detection Cable

Add suffix **"-B"** for blue lens

Wiring Diagram




NOTE: The ProAlert® 2 can be used in more than just leak detection applications. It is an excellent high/low level alarm or any other upset condition.



LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm


Wiring Diagram



LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm

Wiring Diagram




LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm

ICON™ Corrosion-Free
PROCESS CONTROLS Instrumentation Equipment™

Wiring Diagram

For Pulse Input – Relay Output




LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm

ICON™ Corrosion-Free Instrumentation Equipment™
PROCESS CONTROLS

Wiring Diagram



LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm


ICON™ Corrosion-Free
PROCESS CONTROLS Instrumentation Equipment™

Wiring Diagram

**For Pulse Input — Relay Output
(Optional)**



Quick Connect Wiring




LevelPro® — ProAlert® 2

Industrial Visual | Audible Sentry Alarm

ICON™ Corrosion-Free
PROCESS CONTROLS Instrumentation Equipment™

Setup for LDS-YN Leak Detection




PRE-WIRED
NO INTERNAL WIRING NECESSARY

Inside the Pro-Alert® 2 box, the P2R relay has been prewired to a quick connect which the LDS-YN Leak Sensor will connect to.



From the LDS-YN Sensor there is a Blue, Black, and Brown wire and they should attach as follows:

- Blue sensor wire will connect to the Blue quick connect terminal.
- Black sensor wire will connect to the Yellow quick connect terminal.
- Brown sensor wire will connect to the Orange quick connect terminal.



Troubleshooting:

If the sensor is not working properly follow the following steps:

1. If sensor is in constant state of alarm — Place sensor 4" above a cup of water and turn the potentiometer until the system quits alarming. This will calibrate the sensor to detect a liquid 4" from contact.
2. This unit does not provide a 120v output to run to a PLC/Skada system. It only provides a 12-14v output.

